

TMS / ITS - Approved Products List

TMS / ITS Ground Rod Clamp

The Class I rated copper conductor is attached to the 5/8 inch copper clad rod using a clamp that shall meet the following minimum characteristics:

- A.** U.L. approved, heavy duty bronze, two-bolt assembly designed for a 5/8 inch diameter ground rod.
- B.** The set screws shall be 5/16 inch stainless steel hex head bolts.
- C.** A minimum of two inches of positive contact area shall be provided for attaching conductors ranging from No. 6 to 4/0 AWG.